

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**OAK CREEK WATER CO NO 1, PWS # 13041**  
**Has Levels of Arsenic Above Drinking Water Standards**

Our water system Oak Creek Water District recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor of the presence of drinking water contaminants. Testing results we received for the Fourth quarter of 2020 show that our system exceeds the standard, or maximum contaminant level (MCL), for arsenic. The standard for arsenic is 10 parts per billion (ppb). The test results for this quarter were 9.6, 9.9, 10.1 parts per billion.

**What should I do?**

**You do not need to use an alternative (e.g. bottled) water supply.** However, if you have specific health concerns, consult your doctor.

**What does this mean?**

This is not an immediate risk. If it had been you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with circulatory system, and many have an increased risk of getting cancer.

**What is being done?**

We have created a preliminary layout for new arsenic treatment facilities at both well sites. We are working closely with ADEQ and USDA to obtain a low interest rate loan and partial grant. We anticipate obtaining funding and starting construction by late Fall 2020.

For more information, please contact Doug Bowen, Board of Directors President or Jim Reider, Water Operator at (928) 282-3404 or at 90 Oak Creek Blvd., Sedona, AZ 86336.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by Oak Creek Water District, Public Water System ID#: AZ-04-13041. Date distributed: November 20, 2020.

Any ADEQ translation or communication in a language other than English is unofficial and not binding on the State of Arizona.

Cualquier traducción o comunicado de ADEQ en un idioma diferente al inglés no es oficial y no sujetará al Estado de Arizona a ninguna obligación jurídica"