



## Consumer Confidence Report for Calendar Year 2025

Este informe contiene información muy importante sobre el agua usted bebe.  
Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number		Public Water System Name	
AZ04-13-041		Oak Creek Water District	
Contact Name and Title		Phone Number	E-mail Address
Doug Bowen – Chairman / General Manager		928-282-3404	info@oakcreekwater.com
We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or attend any of our regularly scheduled meetings, please contact Oak Creek Water District at 928-282-3404 for additional opportunity and meeting dates and times.			

### Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. To ensure that tap water is safe to drink, EPA prescribes regulations which limit the amounts of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

<b>Our water source(s):</b>	Groundwater
-----------------------------	-------------

### Drinking Water Contaminants

**Microbial Contaminants:** Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

**Inorganic Contaminants:** Such as salts and metals that are naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

**Pesticides and Herbicides:** Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

**Organic Chemical Contaminants:** Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, or could come from gas stations, urban storm water runoff, and septic systems.

**Radioactive Contaminants:** That can be naturally occurring or be the result of oil and gas production and mining activities.

### Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least some small amount contaminant. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised people such as those with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These individuals should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

### Source Water Assessment

Based on the information currently available on the hydrogeologic settings and the adjacent land uses that are in the specified proximity of the drinking water source(s) of this public water system, the Arizona Department of Environmental Quality (ADEQ) has given a high risk designation for the degree to which this public water system drinking water source(s) are protected. A designation of high risk indicates there may be additional source water protection measures which can be implemented on the local level. This does not imply that the source water is contaminated nor does it mean that contamination is imminent. Rather, it simply states that land use activities or hydrogeologic conditions exist that make the source water susceptible to possible future contamination.

## Definitions

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water

**Level 1 Assessment:** A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

**Level 2 Assessment:** A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria was present

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health

**Maximum Residual Disinfectant Level (MRDL):** The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

**Minimum Reporting Limit (MRL):** The smallest measured concentration of a substance that can be reliably measured by a given analytical method

**Millirems per year (MREM):** A measure of radiation absorbed by the body

**Not Applicable (NA):** Sampling was not completed by regulation or was not required

**Not Detected (ND or <):** Not detectable at reporting limit

**Nephelometric Turbidity Units (NTU):** A measure of water clarity

**Million fibers per liter (MFL)**

**Picocuries per liter (pCi/L):** Measure of the radioactivity in water

**ppm:** Parts per million or Milligrams per liter (mg/L)

**ppb:** Parts per billion or Micrograms per liter (µg/L)

**ppt:** Parts per trillion or Nanograms per liter (ng/L)

**ppq:** Parts per quadrillion or Picograms per liter (pg/L)

ppm x 1000 = ppb

ppb x 1000 = ppt

ppt x 1000 = ppq

## Lead Informational Statement:

Oak Creek Water District responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk.

Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water.

To address lead in drinking water, public water systems were required to develop and maintain an inventory of service line materials by Oct 16, 2024. Developing an inventory and identifying the location of lead service lines (LSL) is the first step for beginning LSL replacement and protecting public health. Please contact us if you would like more information about the inventory or any lead sampling that has been done.

If you are concerned about lead in your water and wish to learn more about water testing options, contact us using the information provided at the beginning of this report. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

## Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination
E. Coli	N	0	0	0	0	Human and animal fecal waste
Fecal Indicator (coliphage, enterococci and/or E. coli)	N	0	0	0	0	Human and animal fecal waste
Surface Water Treatment Rule	TT Violation Y or N	Highest Level Detected	% Range (Low-High)	TT	Sample Month & Year	Likely Source of Contamination
Total Organic Carbon <sup>1</sup> (mg/L)	N/A	N/A	N/A	TT		Naturally Present in the Environment
Turbidity <sup>2</sup> (NTU)	N/A	N/A	N/A	TT		Soil runoff

<sup>1</sup> Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THM) and haloacetic acids (HAA). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver, or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

<sup>2</sup> Turbidity is a measure of the cloudiness of water and is an indication of the effectiveness of our filtration system. We monitor it because it is a good indicator of the quality of water. High turbidity can hinder the effectiveness of disinfectants. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N/A	N/A	N/A	4	4		Water additive used to control microbes
Chlorine dioxide (ppb)	N/A	N/A	N/A	800	0		Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	N/A	N/A	N/A	60	N/A		Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N/A	N/A	N/A	80	N/A		Byproduct of drinking water disinfection
Bromate (ppb)	N/A	N/A	N/A	10	0		Byproduct of drinking water disinfection
Chlorite (ppm)	N/A	N/A	N/A	1	0.8		Byproduct of drinking water disinfection
Lead & Copper	MCL Violation Y or N	90 <sup>th</sup> Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	0.12	0	1.3	1.3	7-2025	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	< 5 ppb	0	15	0	7-2025	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	MCL Violation Y or N	Run Annual Ave (RAA) or Highest Level Detected	Range of Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Radium – 226	N	0.125 +/- .0959	0.125		0	2-2025	Decay of natural and man-made deposits
Radium – 228	N	<1.00 +/- 0.289	<1.00		0	2-2025	
Alpha Emitters (pCi/L)	N	1.56 +/- 1.34	1.56	15	0	2-2025	Erosion of natural deposits
Combined Radium-226 & -228 (pCi/L)	N	<1	<1	5	0	2-2025	Erosion of natural deposits
Uranium (ug/L)				30	0		Erosion of natural deposits
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Antimony (ppb)	N	< 0.001	< 0.001	0.006	0.006	2-2025	Discharge from petroleum refineries; fire retardants; ceramics, electronics and solder
Arsenic <sup>1</sup> (ppb)	N	RAA = 6	4.8–9.3 ppb	10	0	2025 Quarterly	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Asbestos (MFL)	N	< 0.2	<0.2	7	7	2-2025	Decay of asbestos cement water mains; Erosion of natural deposits
Barium (ppm)	N	0.22	0.22	2	2	2-2025	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	N	< 0.0003	<0.0003	0.004	0.004	2-2025	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Corrosion of galvanized pipes; natural deposits; metal refineries; runoff from waste batteries and paints
Chromium (ppb)	N	2.5 ppb	2.5 ppb	100	100	2-2025	Discharge from steel and pulp mills; Erosion of natural deposits

Cyanide (ppb)	N	< 0.025	< 0.025	0.2	0.2	2-2025	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
Fluoride (ppm)	N	0.085	0.085	4	4	2-2025	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppb)	N	< 0.0002	< 0.0002	0.002	0.002	2-2025	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills and cropland.
Nitrate <sup>2</sup> (ppm)	N	0.66	0.47-0.66	10	10	2-2025	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (ppm)	N	< 0.050	< 0.050	1	1	2-2025	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nickel	N/A	<0.001	<0.001	N/A	N/A	2-2025	
Selenium (ppb)	N	< 0.002	< 0.002	0.05	0.05	2-2025	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)	N/A	7.4	7.4	N/A	N/A	2-2025	Erosion of natural deposits
Thallium (ppb)	N	< 0.0003	< 0.0003	0.002	0.002	2-2025	Leaching from ore-processing sites; discharged from electronics, glass, and drug factories

<sup>1</sup> Arsenic is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water and continues to research the health effects of low levels of arsenic.

<sup>2</sup> Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

Synthetic Organic Chemicals (SOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
2,4-D (ppb)	N	< 0.0001	< 0.0001	0.07	0.07	2-2025	Runoff from herbicide used on row crops
2,4,5-TP (a.k.a. Silvex) (ppb)	N	< 0.0001	< 0.0001	0.05	0.05	2-2025	Residue of banned herbicide
Acrylamide				TT	0		Added to water during sewage / wastewater treatment
Alachlor (ppb)	N	<0.00005	<0.00005	0.002	0.02	2-2025	Runoff from herbicide used on row crops
Atrazine (ppb)	N	< 0.00005	< 0.00005	0.003	0.003	2-2025	Runoff from herbicide used on row crops
Benzo (a) pyrene (PAH) (ppt)	N	< 0.00002	<0.00002	0.0002	0.0002	2-2025	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	N	< 0.0005	< 0.0005	0.04	0.04	2-2025	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	N	< 0.0001	< 0.0001	0.002	0.002	2-2025	Residue of banned termiticide
Dalapon (ppb)	N	< 0.001	< 0.001	0.2	0.2	2-2025	Runoff from herbicide used on rights of way
Di (2-ethylhexyl) adipate (ppb)	N	< 0.0006	< 0.0006	0.4	0.4	2-2025	Discharge from chemical factories
Di (2-ethylhexyl) phthalate (ppb)	N	< 0.0006	< 0.0006	0.006	0.006	2-2025	Discharge from rubber and chemical factories
Dibromochloropropane (ppt)	N	< 0.00001	< 0.00001	0.002	0.002	2-2025	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, & orchards
Dinoseb (ppb)	N	< 0.0002	<0.0002	0.007	0.007	2-2025	Runoff from herbicide used on soybeans & vegetables
Diquat (ppb)	N	< 0.0004	< 0.0004	0.02	0.02	2-2025	Runoff from herbicide use
Dioxin [a.k.a. 2,3,7,8-TCDD] (ppq)	N	< 5E-9	< 5E-9	3x10-8	3x10-8	2-2025	Emissions from waste incineration and other combustion; discharge from chemical factories
Endothall (ppb)	N	< 0.005	< 0.005	0.1	0.1	2-2025	Runoff from herbicide use
Endrin (ppb)	N	< 0.00001	< 0.00001	0.002	0.002	2-2025	Residue of banned insecticide
Epichlorohydrin				TT	0		Discharge from industrial chemical factories; an impurity of some water treatment chemicals
Ethylene dibromide (ppt)	N	< 0.00001	< 0.00001	0.00005	0.00005	2-2025	Discharge from petroleum refineries
Glyphosate (ppb)	N	< 0.006	< 0.006	0.7	0.7	2-2025	Runoff from herbicide use

Heptachlor (ppt)	N	< 0.00001	< 0.00001	0.0004	0.0004	2-2025	Residue of banned termiticide
Heptachlor epoxide (ppt)	N	< 0.00001	< 0.00001	0.0002	0.0002	2-2025	Breakdown of heptachlor
Hexachlorobenzene (ppb)	N	< 0.00005	< 0.00005	0.001	0.001	2-2025	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclo pentadiene (ppb)	N	< 0.00005	< 0.00005	0.05	0.05	2-2025	Discharge from chemical factories
Lindane (ppt)	N	< 0.00001	< 0.00001	0.0002	0.0002	2-2025	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	N	< 0.00005	< 0.00005	0.04	0.04	2-2025	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa,
Oxamyl (a.k.a. Vydate) (ppb)	N	< 0.0005	< 0.0005	0.2	0.2	2-2025	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
PCBs [Polychlorinated biphenyls] (ppt)	N	< 100	< 100	500	0	11-2019	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol (ppb)	N	< 0.00004	< 0.00004	0.001	0.001	2-2025	Discharge from wood preserving factories
Picloram (ppb)	N	< 0.0001	< 0.0001	0.5	0.5	2-2025	Herbicide runoff
Simazine (ppb)	N	< 0.00005	< 0.00005	0.004	0.004	2-2025	Herbicide runoff
Toxaphene (ppb)	N	< 0.0005	< 0.0005	0.003	0.003	2-2025	Runoff/leaching from insecticide used on cotton and cattle
<b>Volatile Organic Chemicals (VOC)</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Benzene (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	N	< 0.0005	< 0.0005	0.1	0.1	2-2025	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	N	< 0.0005	< 0.0005	0.6	0.6	2-2025	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	N	< 0.0005	< 0.0005	0.075	0.075	2-2025	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	N	< 0.0005	< 0.0005	0.007	0.007	2-2025	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	N	< 0.0005	< 0.0005	0.07	0.07	2-2025	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	N	< 0.0005	< 0.0005	0.1	0.1	2-2025	Discharge from industrial chemical factories
Dichloromethane (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Discharge from industrial chemical factories
Ethylbenzene (ppb)	N	< 0.0005	< 0.0005	0.7	0.7	2-2025	Discharge from petroleum refineries
Styrene (ppb)	N	< 0.0005	< 0.0005	0.1	0.1	2-2025	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	N	< 0.0005	< 0.0005	0.07	0.07	2-2025	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	N	< 0.0005	< 0.0005	0.2	0.2	2-2025	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Discharge from industrial chemical factories
Trichloroethylene (ppb)	N	< 0.0005	< 0.0005	0.005	0.005	2-2025	Discharge from metal degreasing sites and other factories
Toluene (ppm)	N	< 0.0005	< 0.0005	1	1	2-2025	Discharge from petroleum factories
Vinyl Chloride (ppb)	N	< 0.0003	< 0.0003	0.002	0.002	2-2025	Leaching from PVC piping; discharge from chemical factories
Xylenes (ppm)	N	< 0.0005	< 0.0005	10	10	2-2025	Discharge from petroleum or chemical factories

## Water Quality Table – Unregulated Contaminants

Your drinking water was sampled for the presence and concentration of 29 different per- and polyfluoroalkyl substances, some known by the acronyms PFAS, PFOA, PFNA, PFHxS, PFBS, and GenX, a group of contaminants in the final stages of becoming regulated by the EPA. PFAS are man-made chemicals that are resistant to heat, water, and oil. They have been used since the 1940s to manufacture various consumer products, including fire-fighting foam and stain resistant, water-resistant, and nonstick items. Many PFAS do not break down easily and can build up in people, animals, and the environment over time. Scientific studies have shown that exposure to certain PFAS can be harmful to people and animals, depending on the level and duration of exposure.

To learn more about this group of chemicals, we encourage you to read the ADEQ-provided “PFAS 101 Fact Sheet” and to visit the ADEQ website at <https://www.azdeq.gov/pfas-resources>

Per- and Polyfluoroalkyl Substances	Highest Level Detected	Range of All Samples	Proposed MCL
PFOA (in parts per trillion)			4.0 ppt
PFOS (in parts per trillion)			4.0 ppt
PFNA (in parts per trillion)			N/A*
PFHxS (in parts per trillion)			N/A*
PFBS (in parts per trillion)			N/A*
GenX (in parts per trillion)			N/A*
Calculated Hazard Index (HI)			1 (no units)

\* EPA is proposing a Hazard Index MCL to limit any mixture containing one or more of PFNA, PFHxS, PFBS, and/or GenX Chemicals. The Hazard Index considers the different toxicities of PFNA, GenX Chemicals, PFHxS, and PFBS. For these PFAS, water systems would use a hazard index calculation to determine if the combined levels of these PFAS in the drinking water at that system pose a potential risk & require action (Source: EPA Fact Sheet: Understanding PFAS National Primary Drinking Water Proposal Hazard Index).

## Water Quality Table - Unregulated Contaminant Monitoring Rule (Required Reporting)

Twenty-nine Per- and Polyfluoroalkyl Substances (In parts per trillion)	Detected (Y/N)	Average of Results (ppt)	Range of All Samples (Low-High)	Minimum Reporting Level (ppt)	Analytical Methods
11-chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	Y	4.60	4.56-4.63	5	EPA 533
1H, 1H, 2H, 2H-perfluorodecane sulfonic acid (8:2 FTS)	Y	4.60	4.56-4.63	5	EPA 533
1H, 1H, 2H, 2H-perfluorohexane sulfonic acid (4:2 FTS)	Y	2.76	2.74-2.78	3	EPA 533
1H, 1H, 2H, 2H-perfluorooctane sulfonic acid (6:2 FTS)	Y	4.60	4.56-4.63	5	EPA 533
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	Y	2.76	2.74-2.78	3	EPA 533
9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)	Y	1.84	1.82-1.85	2	EPA 533
hexafluoropropylene oxide dimer acid (HFPO-DA) (GenX)	Y	4.60	4.56-4.63	5	EPA 533
nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	Y	18.4	18.2-18.5	20	EPA 533
Perfluoro-3-methoxypropanoic acid (PFMPA)	Y	3.68	3.65-3.70	3	EPA 533
Perfluoro-4-methoxybutanoic acid (PFMBA)	Y	2.76	2.74-2.78	4	EPA 533
Perfluorobutanesulfonic acid (PFBS)	Y	3.39	2.74-4.07	3	EPA 533
Perfluorobutanoic acid (PFBA)	Y	4.60	4.56-4.63	5	EPA 533
Perfluorodecanoic acid (PFDA)	Y	2.76	2.74-2.78	3	EPA 533
Perfluorododecanoic acid (PFDoA)	Y	2.76	2.74-2.78	3	EPA 533
Perfluoroheptanesulfonic acid (PFHpS)	Y	2.76	2.74-2.78	3	EPA 533
Perfluoroheptanoic acid (PFHpA)	Y	2.76	2.74-2.78	3	EPA 533
Perfluorohexanesulfonic acid (PFHxS)	Y	2.76	2.74-2.78	3	EPA 533

Perfluorohexanoic acid (PFHxA)	Y	4.8	2.74-6.37	3	EPA 533
Perfluorononanoic acid (PFNA)	Y	3.68	3.65-3.70	4	EPA 533
Perfluorooctanesulfonic acid (PFOS)	Y	3.68	3.65-3.70	4	EPA 533
Perfluorooctanoic acid (PFOA)	Y	3.68	3.65-3.70	4	EPA 533
Perfluoropentanesulfonic acid (PFPeS)	Y	3.68	3.65-3.70	4	EPA 533
Perfluoropentanoic acid (PFPeA)	Y	4.08	2.74-5.22	3	EPA 533
Perfluoroundecanoic acid (PFUnA)	Y	1.84	1.82-1.85	2	EPA 533
n-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	Y	1.88	1.87-1.89	5	EPA 537.1
n-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	Y	1.88	1.87-1.89	6	EPA 537.1
Perfluorotetradecanoic acid (PFTA)	Y	1.88	1.87-1.89	8	EPA 537.1
Perfluorotridecanoic acid (PFTTrDA)	Y	1.88	1.87-1.89	7	EPA 537.1
<b>One Metal</b>	<b>Detected (Y/N)</b>	<b>Average</b>	<b>Range of All Samples (Low-High)</b>	<b>MRL (ppb)</b>	<b>Analytical Methods</b>
Lithium (ppb)				9 µg/L	EPA 200.7, SM 3120 B, ASTM D1976-20

#### Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement)

Violation Type	Explanation, Health Effects	Time Period	Corrective Actions
Our System is happy to report we did not incur any violations in 2025			
Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.			

#### Assessments for the Revised Total Coliform Rule (RTCR)

**Coliforms** are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. If coliform is found, then the system is responsible to look for potential problems in water treatment or distribution. When this occurs, the water system is required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

- During the past year, we were required to conduct [ 2 ] Level 2 assessment(s). [ 2 ] Level 2 assessment(s) were completed. In addition, we were required to take [ 0 ] corrective actions and we completed [ 0 ] of these actions.:

**E. coli** are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. If *E. coli* bacteria is found, the water system is required to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

- During the past year, we were required to complete [ 0 ] Level 2 assessment(s) because we found *E. coli* in our water system. In addition, we were required to take [ 0 ] corrective actions and we completed [ 0 ] of these actions.

#### Failure to Conduct Assessments for the Revised Total Coliform Rule

Contaminant Name	TT Violation Y or N	TT Requirement
<b>Total Coliform</b>	N	<p>We were required to conduct an assessment of our system due to one of the following:</p> <ul style="list-style-type: none"> <li>• More than 5.0% positive samples per period (if the number of samples are greater than or equal to 40)</li> <li>• <u>OR</u> More than 1 positive sample per period(if the number of samples less than 40)</li> <li>• <u>OR</u> Repeat samples not collected after positive sample.</li> </ul>